



ADDENDUM NUMBER ONE

May 23, 2016

**RFQ #16-912-14;
AUTOMATION OF HVAC SYSTEMS AT GUSTE HIGH RISE**

THIS ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING IN THE REFERENCED REQUEST FOR QUOTES

ITEM #1 BID DUE DATE AND TIME

DELETE: Tuesday, May 24, 2016 @ 2:00 P.M.

INSERT: Friday, May 27, 2016 @ 2:00 P.M.

ITEM #2 QUESTIONS RECEIVED

Q1: Is a bid bond required for this bid?

A1: Yes. Refer to the Instructions to Bidders for Contracts, Clause 9, Bid Guarantee, in the project manual.

Q2: Page 230900-10 of the specifications only allow the following vendors:

1. Tridium (Niagara) platform FX-60
2. Trane Tracer
3. Trane Connectivity Module

We respectfully request approval of our Siemens Apogee System. Our system meets all the requirements of the bid relative to BACnet and the other required specifications.

A2: Refer to Item #3 of this Addendum.

Item #3 APPROVED CONTROL SYSTEM MANUFACTURERS

INSERT: In section 230900 of the specifications, Instrumentation and Control for HVAC, subsection 1.3, Approved Control System Manufacturers, add the following:

C. Siemens or "equal".

Quotes must be received by the Housing Authority of New Orleans (HANO) in the Department of Procurement and Contracts by 2:00 p.m. CST on Friday, May 27, 2016. All terms and conditions shall remain as stated in the original Request for Quotes. All addenda must be acknowledged.

END OF ADDENDUM NUMBER ONE