



## ADDENDUM NUMBER FOUR

June 26, 2017

**RFQ #17-910-13  
DATA RECOVERY SITE FOR HANO IT DEPARTMENT**

THIS ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING IN THE REFERENCED REQUEST FOR QUOTES.

**Item #1 WRITTEN QUESTIONS RECEIVED**

**Q1: What are the power requirements per rack for the equipment you will collocate?**

A1: Each rack would require between .6 kw and 1.2 kw AC on average

**Q2: Can you please provide additional information to define "business continuance"? What capabilities does the include? For example, do you need the collocated equipment to be available to you in the event HANO offices and datacenter are offline?**

A2: The co-located equipment will provide an offsite backup of select HANO data, it does need to be immediately accessible in the event HANO offices and datacenter are offline due to a real-world or data-related disaster where restoration of the offsite data is the desired option for business continuance. Our Disaster Recovery plan involves the retrieval of the data from the remote site and installation of the data on servers hosted locally.

**Quotes must be received by the Housing Authority of New Orleans (HANO) in the Office of Procurement and Contracts by 2:00 p.m., local time on Friday, June 30, 2017. All terms and conditions shall remain as stated in the original Request for Quotes. All addenda must be acknowledged.**

**END OF ADDENDUM NUMBER FOUR**